

TEST REPORT

Report No: G&C/AS/03/2018/163

Date: 16.03.2018

Name & Address of Customer: M/s. DYNAMIC SOLAR INTERNATIONAL, Office No. 16, 3rd Floor, 64-West
Maslow Plaza, Jinnah Avenue, Islamabad.

Request Ref. # & Date: Nil dated 27.02.2018 Sheet No: 1

Description of Sample: Roof Insulation Material No. Of Sample(s): One

ILO Log # and Date: 1379 dated 27.02.2018 Ref/Code #: 36/2018

Method used /Specs: ASTM C-642 Temp. & Humidity: NA

Statement of Non-compliance: Nil Testing Date: 01-16/03/2018

RESULTS

Apparent Density of Hardened Material (25mm thick) = 2.79 g/cm³

◆.....◆END◆.....◆

- This test/calibration certificate is based solely on the particular sample(s) supplied by the client and should not be reported in part.
- Sampling has not been performed by the PCSIR Labs and PCSIR does not accept the responsibility that the item(s) supplied is/are truly representative item(s) of any batch or stock or entire production.
- While the PCSIR agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability there of beyond the amount of the fee charged for the analysis/test.
- The party shall assume full responsibility for the ethical use of the results in the test/calibration certificate and the laboratory shall be held free from any and all claims, which may result from the use of such data by the client or others.
- After completion of the test/calibration the sample, if required, will be retained for one month until negotiated otherwise.
- The contents of this certificate cannot be, in any manner, used for the publicity of the product or any advertisement.
- Uncertainty of measurements can be provided on request.



Prepared by:

AKHTAR SHAHNAZ
Scientific Officer
Section Incharge

DR. BAKHT BAHADUR RANA
Principal Scientific Officer
Head of the Centre

Counter signature

16-3-18
Director General



Tel: +92 42 99231798; PABX No.+92 42 99230688 - 95 Fax: + 92 42 99230705
Email: ilo@pcsir-lhr.gov.pk; website: www.pcsir-lhr.gov.pk.





Pakistan Council of Scientific & Industrial Research
Laboratories Complex, Lahore

FEROZEPUR ROAD, LAHORE 54600 - PAKISTAN

Doc# LLC/QMR/FF/030A Issue Date: Jan 4th 2013 Issue # 01 Rev # 02



TEST REPORT

Report No: G&C/AS/03/2018/165

Date: 16.03.2018

Name & Address of Customer: M/s. DYNAMIC SOLAR INTERNATIONAL, Office No. 16, 3rd Floor, 64-West
Maslow Plaza, Jinnah Avenue, Islamabad.

Request Ref. # & Date: Nil dated 27.02.2018 Sheet No: 1

Description of Sample: Roof Insulation Material No. Of Sample(s): One

ILO Log # and Date: 1381 dated 27.02.2018 Ref/Code #: 38/2018

Method used /Specs: ASTM C-642 Temp. & Humidity: NA


Statement of Non-compliance: Nil Testing Date: 01-16/03/2018

RESULTS

Apparent Density of Hardened Material (12mm thick) = 2.74 g/cm³

◆-----◆END◆-----◆

- This test/calibration certificate is based solely on the particular sample(s) supplied by the client and should not be reported in part.
- Sampling has not been performed by the PCSIR Labs and PCSIR does not accept the responsibility that the item(s) supplied is/are truly representative item(s) of any batch or stock or entire production.
- While the PCSIR agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability there of beyond the amount of the fee charged for the analysis/test.
- The party shall assume full responsibility for the ethical use of the results in the test/calibration certificate and the laboratory shall be held free from any and all claims, which may result from the use of such data by the client or others.
- After completion of the test/calibration the sample, if required, will be retained for one month until negotiated otherwise.
- The contents of this certificate cannot be, in any manner, used for the publicity of the product or any advertisement.
- Uncertainty of measurements can be provided on request.



Prepared by:

AKHTAR SHAHNAZ
Scientific Officer
Section Incharge

DR. BAKHT BAHADUR RANA
Principal Scientific Officer
Head of the Centre

Counter signature

Shahid
16-3-18
Director General

Tel: +92 42 99231798; PABX No.+92 42 99230688 - 95 Fax: + 92 42 99230705
Email: ilo@pcsir-lhr.gov.pk; website: www.pcsir-lhr.gov.pk.





TEST REPORT

Report No: G&C/AS/03/2018/164

Date: 16.03.2018

Name & Address of Customer: M/s. DYNAMIC SOLAR INTERNATIONAL, Office No. 16, 3rd Floor, 64-West
Maslow Plaza, Jinnah Avenue, Islamabad.

Request Ref. # & Date: Nil dated 27.02.2018 Sheet No: 1

Description of Sample: Roof Insulation Material No. Of Sample(s): One

ILO Log # and Date: 1380 dated 27.02.2018 Ref/Code #: 37/2018

Method used /Specs: ASTM C-642 Temp. & Humidity: NA

Statement of Non-compliance: Nil Testing Date: 01-16/03/2018

RESULTS

Apparent Density of Hardened Material (19mm thick) = 2.76 g/cm³

◆-----◆END◆-----◆

- This test/calibration certificate is based solely on the particular sample(s) supplied by the client and should not be reported in part.
- Sampling has not been performed by the PCSIR Labs and PCSIR does not accept the responsibility that the item(s) supplied is/are truly representative item(s) of any batch or stock or entire production.
- While the PCSIR agrees to take every reasonable precaution to ensure validity of its test results, it assumes no liability there of beyond the amount of the fee charged for the analysis/test.
- The party shall assume full responsibility for the ethical use of the results in the test/calibration certificate and the laboratory shall be held free from any and all claims, which may result from the use of such data by the client or others.
- After completion of the test/calibration the sample, if required, will be retained for one month until negotiated otherwise.
- The contents of this certificate cannot be, in any manner, used for the publicity of the product or any advertisement.
- Uncertainty of measurements can be provided on request.



Prepared by:

AKHTAR SHAHNAZ
Scientific Officer
Section Incharge

DR. BAKHT BAHADUR RANA
Principal Scientific Officer
Head of the Centre

Counter signature

Signature
16-3-18
Director General

+92 42 99231798; PABX No.+92 42 99230688 - 95 Fax: +92 42 99230705
Email: ilo@pcsir-lhr.gov.pk; website: www.pcsir-lhr.gov.pk.

